



# REQUIRED LABELING FOR PHOTOVOLTAIC SYSTEMS

**BUILDING SERVICES**



Labeling shall comply with CEC Sections 690-5c, 690-10c, 690-17

Labels shall be printed or manufactured so as to be permanent and shall not discolor or be subject to deterioration from exterior / weather conditions. Hand written marker pen labeling will not be allowed.

**WARNING**

SINGLE 120 VOLT SUPPLY  
DO NOT CONNECT MULTI-WIRE  
BRANCH CIRCUITS

SINGLE SOURCE SYSTEMS ONLY

**DISCONNECT**

Photovoltaic system from utility

TO BE PLACED ON THE  
PHOTOVOLTAIC SYSTEM  
DISCONNECT TO THE MAIN  
ELECTRICAL SERVICE

**-WARNING-**

**MULTIPLE POWER  
SOURCES**

A PHOTOVOLTAIC SYSTEM  
IS PRESENT.

120 VAC and / or 240VAC  
may be produced.

DC power circuits  
are present on this site.

Batteries may be present on this site.

Disconnect all power sources  
before servicing.

Test all voltages  
to confirm disconnection.

TO BE PLACED ON MAIN ELECTRICAL  
PANEL COVER

**-WARNING-**

**ELECTRIC SHOCK  
HAZARD**

- Do not touch terminals -  
Terminals on BOTH the line and  
load sides may be energized  
in the open position.

TO BE PLACED ON THE  
DISCONNECT FROM THE  
SOLAR PANELS TO THE  
PHOTOVOLTAIC SYSTEM