



PHOTOVOLTAIC SYSTEMS SUBMITTAL REQUIREMENTS

BUILDING SERVICES



General Requirements

The design and installation must comply with the 2013 California Building Code (CBC), 2013 California Residential Code (CRC), 2013 California Electrical Code (CEC), 2013 California Mechanical Code (CMC), 2013 California Plumbing Code (CPC). All components and equipment used in the photovoltaic system must be installed in accordance with its listing and the manufacturers installation instructions.

Plan Requirements (SUBMIT 3 DRAWINGS, 11"X17" MINIMUM, 24"X36" MAXIMUM SIZE)

- Installation of the PV system shall be in conformance with CEC Article 690 and CRC R331.
- Plot plan showing the property boundaries, all buildings located on the parcel, easements, etc.
- Roof Plan view of PV System panels; also indicate the dimension and layout of the existing roof framing members.
- Clearly show the location of the electrical service, including amperage rating.
- Provide details on the mounting of PV modules including type and number of roof coverings, including method of weather and water proofing.
- Provide device listing for the method of bonding PV modules.
- Include a torque schedule for all equipment connections including; inverter mounting hardware, disconnects, breakers, module clips, lug and panel hardware, inverter connections, racking system. This information shall be provided in either inch/lbs. or ft./lbs.
- Provide an electrical single-line diagram identifying all devices in the system including the total kVA rating.
- Show the type and size of conductors and conduits.
- Provide manufacturer specifications and installation instructions for the modules, mounting systems, inverters, disconnects, transformers, batteries, generators, etc.
- Provide structural calculations, prepared by a registered California design professional if the total weight of the PV system exceeds 5 pounds per square foot.
- If ground-mounted system, indicate configuration of structural frame-work including foundation system, framing material type with dimensions, and fasteners. In addition, provide structural specifications for panel support.
- Provide exterior elevations showing arrangement of each listed electrical panel and associated components.
- Provide identification and warning signage in conformance with CEC Article 690.

Battery Installation

- Provide floor plan of structure used to house battery bank.
- Indicate battery type, size, dimensions, ventilation, and protection from physical damage.
- Provide method for battery bank anchoring.
- Provide wiring diagram of battery set.

The following information indicates the required roof top clearances for panels/arrays installed on residential buildings with slopes greater than 2:12:

Roof access points. Roof access points shall be located in areas that do not require the placement of ground ladders over openings such as windows or doors, and located at strong points of building construction in locations where the access point does not conflict with overhead obstructions such as tree limbs, wires or signs.

Residential buildings with hip roof layouts. Panels/modules installed on residential buildings with hip roof layouts shall be located in a manner that provides a 3-foot-wide clear access pathway from the eave to the ridge on each roof slope where panels/modules are located. The access pathway shall be located at a structurally strong location on the building capable of supporting the live load of fire fighters accessing the roof.

Residential buildings with a single ridge. Panels/modules installed on residential buildings with a single ridge shall be located in a manner that provides two, 3-foot-wide access pathways from the eave to the ridge on each roof slope where panels/modules are located.

Residential buildings with roof hips and valleys. Panels/modules installed on residential buildings with roof hips and valleys shall be located no closer than 18 inches to a hip or a valley where panels/modules are to be placed on both sides of a hip or valley. Where panels are to be located on only one side of a hip or valley that is of equal length, the panels shall be permitted to be placed directly adjacent to the hip or valley.

Residential building smoke ventilation. Panels/modules installed on residential buildings shall be located no higher than 3 feet below the ridge in order to allow for fire department smoke ventilation operations.

Ground-mounted photovoltaic arrays. Ground-mounted photovoltaic arrays shall require a clear, brush-free area of at least 10 feet.